

COPY



TOWN OF GRAFTON

26 Upton Street

GRAFTON, MASSACHUSETTS 01519

Phone: (508) 839-4606 ext 222 • FAX: (508) 839-8520

Email: barker@grafton-ma.gov

RECEIVED

MAY - 9 2019

**PLANNING BOARD
GRAFTON, MA**

Michael E. Gauthier
Fire Chief

EXHIBIT 4

May 9, 2019

Grafton Planning Board
Municipal Center
30 Providence Road
Grafton, Massachusetts 01519

Ref: 155 George Hill Rd Solar Facility

Dear Board Members:

The Grafton Fire Department has reviewed the plans dated April 24, 2019. The access road must be constructed to an unobstructed width of not less than 20 feet [NFPA 2015 section 18.2.3.4.1.1]. The access road must have an unobstructed vertical clearance of not less than 13ft 6 in. [NFPA 2015 section 18.2.3.4.1.2}. The access road must be designed and maintained to allow fire apparatus to travel the entire road, in all seasons. Fire Department would also like to have a Knox Box installed at the gate to the Solar Panel Array area.

There also should be a plan to maintain vegetation within and adjacent to the proposed photovoltaic field and proposed access road.

Yours truly,

A handwritten signature in cursive script that reads "Stephen L. Charest".

Stephen L Charest,
Inspector
Grafton Fire Department